



DANAK
TEST Reg. nr. 361

Ordrenr: 841204
Sagsnavn: Svanholm Gods vv

ALS Denmark A/S
Bakkegårdsvej 406 A
DK-3050 Humlebæk
Telefon: +45 4925 0770
www.alsglobal.dk

ANALYSERAPPORT

Svanholm Gods
v/Jarnved K/S
Svanholm Gods 4A
4050 Skibby

Udskrevet: 16-04-2024
Version: 1
Modtaget: 20-03-2024
Analyseperiode: 20-03-2024 -
16-04-2024
Ordrenr.: 841204

Sagsnavn: Svanholm Gods vv
Lokalitet: Svanholm Gods, VV
Prøvested: Svanholm Gods 4A
Prøve ID: Køkkenhane - m flush
Udtaget: 20.03.2024 kl. 11:07:00
Prøvetype: Drikkevand - Bek. 507:2023, Gruppe B
Prøvetager: LAB/DBH
Kunde: Svanholm Gods
v/Jarnved K/S, Svanholm Gods 4A, 4050 Skibby, Att.

Prøvenr.:	41998/24				
Parameter	Resultat	Enhed	Metode	Grænseværdi	Forbruger taphane jvf BEK 1023:2023
Partikler i prøve efter konservering	#	Nej	-	-	
Prøvetagning, Taphane (m. flush)		+	- DS/EN ISO 19458:2006, MST Manual for DRV version 5, 2021, DS/ISO 5667-5:2006		
Lugt	#	Ingen lugt (1)	Ingen	-	Vandet må ikke have en afvigende smag og lugt, desinfektionsmidler undtaget
Smag	#	Ingen (1)	Ingen	-	Vandet må ikke have en afvigende smag og lugt, desinfektionsmidler undtaget
Gennemskylningstid		12	min	Målt i felten	Gennemskyldning min. 5 minutter
pH ved prøvetagning		7.4	pH	DS/EN ISO 10523:2012	7 - 8.5
Temperatur ved prøvetagning		8.5	°C	-	-
Ledningsevne v. ptagning		61	mS/m	DS/EN 27888:2003	30 mS/m
Intestinale Enterokokker		<1	cfu/100 ml	DS/EN ISO 7899-2:2000	<1
Kimtal ved 22 °C		1	cfu/ml	DS/EN ISO 6222:2000/Till.1:2002	200
Coliforme bakterier		<1	cfu/100 ml	DS/EN ISO 9308-1:2014/A1:2017	<1
E. Coli		<1	cfu/100 ml	DS/EN ISO 9308-1:2014/A1:2017	<1
Turbiditet		0.17	FNU	DS/EN ISO 7027-1:2016	1 FNU
Mangan, Mn		0.0020	mg/l	DS/EN ISO 11885:2009	0.05 mg/l
Natrium, Na+		12	mg/l	DS/EN ISO 11885:2009	175 mg/l
Jern, Fe		0.037	mg/l	DS/EN ISO 11885:2009	0.2 mg/l
Ammonium+ammoniak, NH4+		<0.0040	mg/l	DS/ISO 15923-1:2013+DS224:1975Mod	0.05 mg/l
Nitrit, NO2-		<0.0010	mg/l	DS/ISO 15923-1:2013	0.1 mg/l
Nitrat, NO3-		0.65	mg/l	DS/ISO 15923-1:2013 + beregning	50 mg/l
Chlorid, Cl-		26	mg/l	DS/ISO 15923-1:2013	250 mg/l
Fluorid, F-		0.22	mg/l	DS 218:1975,MOD	1.5 mg/l
Sulfat, SO4--		66	mg/l	DS/ISO 15923-1:2013	250 mg/l
Farvetal, Pt		2.9	Pt mg/l	DS/EN ISO 7887 C:2012	15 mg Pt/l
NVOC		1.5	mg/l	DS/EN 1484:1997+SM 5310B:2014	4 mg/l
Cyanid CN, total		<1.0	µg/l	DS/EN ISO 14403-2:2012	50 µg/l
Aluminium, Al		<0.50	µg/l	DS/EN ISO 17294-2:2016	200 µg/l
Antimon, Sb		<0.20	µg/l	DS/EN ISO 17294-2:2016	5 µg/l
Arsen, As		0.11	µg/l	DS/EN ISO 17294-2:2016	5 µg/l
Bly, Pb		0.093	µg/l	DS/EN ISO 17294-2:2016	5 µg/l

side 1 af 3

Laboratoriet er akkrediteret af DANAK. Analyseresultaterne gælder kun for de(n) analyserede prøve(r). Analyserapporten må kun gengives i sin helhed, medmindre skriftlig godkendelse foreligger. Oplysninger om måleusikkerhed findes på www.alsglobal.dk

Tegnforklaring, Resultat:
i.p.: Ikke påvist, -: analysen er ikke udført
i rapporten betyder ikke akkrediteret



DANAK
TEST Reg nr. 361

Ordrenr: 841204
Sagsnavn: Svanholm Gods vv

ALS Denmark A/S
Bakkegårdsvej 406 A
DK-3050 Humlebæk
Telefon: +45 4925 0770
www.alsglobal.dk

ANALYSERAPPORT

Prøvenr.:	41998/24				
Parameter	Resultat	Enhed	Metode	Grænseværdi Forbruger taphane jvf BEK 1023:2023	
Bor, B	44	µg/l	DS/EN ISO 11885:2009	1000 µg/l	
Cadmium, Cd	0.0033	µg/l	DS/EN ISO 17294-2:2016	3 µg/l	
Chrom, Cr	<0.030	µg/l	DS/EN ISO 17294-2:2016	25 µg/l	
Kobolt, Co	<0.030	µg/l	DS/EN ISO 17294-2:2016	5 µg/l	
Kobber, Cu	3.7	µg/l	DS/EN ISO 17294-2:2016	2000 µg/l	
Kviksølv, Hg	<0.0010	µg/l	DS/EN ISO 17852:2008	1 µg/l	
Nikkel, Ni	0.062	µg/l	DS/EN ISO 17294-2:2016	20 µg/l	
Selen, Se	<0.050	µg/l	DS/EN ISO 17294-2:2016	10 µg/l	
Zink, Zn	20	µg/l	DS/EN ISO 17294-2:2016	3000 µg/l	
HS drikkevand					
Benzen	<0.020	µg/l	DS/EN ISO 10301:2000	1 µg/l	
HS chlor. nedbryd.					
Trichlormethan (Chloroform)	<0.020	µg/l	DS/EN ISO 10301:2000	1 µg/l	
1,1,1-trichlorethan	<0.020	µg/l	DS/EN ISO 10301:2000	1 µg/l	
1,1,2-trichlorethan	<0.020	µg/l	DS/EN ISO 10301:2000	1 µg/l	
Trichlorethylen	<0.020	µg/l	DS/EN ISO 10301:2000	1 µg/l	
Tetrachlorethylen	<0.020	µg/l	DS/EN ISO 10301:2000	1 µg/l	
Vinylchlorid	<0.020	µg/l	DS/EN ISO 10301:2000	0.5 µg/l	
1,1-dichlorethylen	<0.020	µg/l	DS/EN ISO 10301:2000	1 µg/l	
trans-1,2-dichlorethylen	<0.020	µg/l	DS/EN ISO 10301:2000	1 µg/l	
cis-1,2-dichlorethylen	<0.020	µg/l	DS/EN ISO 10301:2000	1 µg/l	
1,2-dichlorethan	<0.020	µg/l	DS/EN ISO 10301:2000	1.0 µg/l	
Dichlormethan	<0.10	µg/l	DS/EN ISO 10301:2000	1 µg/l	
Epichlorhydrin	*1	<0.050	µg/l	Underleverandør - GC/MS	0.1 µg/l
2,6-dichlorphenol	<0.010	µg/l	AK158 - GC/MS	0.1 µg/l	
1,2,4-triazol	<0.010	µg/l	AK207 - LC/MS/MS	0.1 µg/l	
Acrylamid	*1	<0.050	µg/l	Underleverandør - LC/MS/MS	0.1 µg/l
				Anvendelse af kemikalier med indhold heraf bør undgås til vandbehandling	
Pesticider, Drikkevand grundpakke LC/MS			-	-- LC/MS/MS	
Pesticider, Drikkevand grundpakke GC/MS			-	-- GC/MS	
Pesticider, vand chloridazon samt nedbr.			-	-- LC/MS/MS	
2,6-DCPP (2-(2,6-dichlorphenoxy-propionsyre)), 2,6-dichlorprop	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
4-CPP, (4-Chlorprop)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Aminomethylphosphorsyre, AMPA	<0.010	µg/l	AK144 - LC/MS/MS	0.1 µg/l	
Atrazin	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Bentazon	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
2,6-Dichlorbenzamid (BAM)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Chloridazon	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
ETU (Ethylthiourea)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
2,6-dichlorbenzoesyre	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Desphenyl-chloridazon, DPC	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Imazalil	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Methyl-desphenyl-chloridazon	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
4-nitrophenol	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
2,4-dichlorphenol	<0.010	µg/l	AK158 - GC/MS	0.1 µg/l	
Desethylatrazin	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Desethyl-desisopropylatrazin (DEIA)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Desethyl-hydroxy-atrazin	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Desethylterbutylazin	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Desisopropylatrazin	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Desisopropyl-hydroxy-atrazin	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Dichlobenil	<0.010	µg/l	AK78 - GC/MS	0.1 µg/l	
Dichlorprop(2,4-DP)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Didealkyl-hydroxy-atrazin	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Glyphosat	<0.010	µg/l	AK144 - LC/MS/MS	0.1 µg/l	
Hexazinon	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	

side 2 af 3

Laboratoriet er akkrediteret af DANAK. Analyseresultaterne gælder kun for de(n) analyserede prøve(r). Analyserapporten må kun gengives i sin helhed, medmindre skriftlig godkendelse foreligger. Oplysninger om måleusikkerhed findes på www.alsglobal.dk

Tegnforklaring, Resultat:
i.p.: Ikke påvist, -: analysen er ikke udført
i rapporten betyder ikke akkrediteret



DANAK
TEST Reg nr. 361

Ordrenr: 841204
Sagsnavn: Svanholm Gods vv

ALS Denmark A/S
Bakkegårdsvej 406 A
DK-3050 Humlebæk
Telefon: +45 4925 0770
www.alsglobal.dk

ANALYSERAPPORT

Prøvenr.:	41998/24				
Parameter	Resultat	Enhed	Metode	Grænseværdi	Forbruger taphane jvf BEK 1023:2023
Hydroxyatrazin	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Hydroxysimazin	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
MCPA	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Mechlorprop(MCPP)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Metamitron-desamino	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
PPU (IN 70941), (Nedbr. af Rimsulfuron)	<0.010	µg/l	AK78 - LC/MS/MS		
Simazin	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
TFMP	<0.010	µg/l	AK78 - LC/MS/MS		
Pentachlorbenzen	<0.010	µg/l	AK158 - GC/MS/SIM		
N,N-Dimethylsulfamid (DMS)	<0.010	µg/l	AK207 - LC/MS/MS	0.1 µg/l	
Chlorothalonilamid-sulfonsyre (R417888)	<0.0050	µg/l	AK78 - LC/MS/MS	0,1 µg/l	
Pesticider, DRV BEK 1023:2023		-	- - LC/MS/MS		
Alachlor ESA	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Dimethachlor ESA	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Dimethachlor OA (CGA 50266)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Metazachlor ESA	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Metazachlor OA	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Propachlor ESA	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
t-Sulfinyledikesyre (Acetochlor SAA)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
CGA 369873 (Dimethachlor metab.)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
[(2,6-Dimethylphenyl)(2-sulfoacetyl)amino]eddikesyre	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Metaldehyd	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
Monuron	<0.010	µg/l	AK78 - LC/MS/MS		
4-Bis-amido-3,5,6-trichlorobenzenesulfonat (R471811) (Nedbr. af Chlorothalonil)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
6-(tert-Butylamino)-1,3,5-triazine-2,4-diol (CGA324007, LM5, nedbr. af Terbutylazin)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
4-(tert-Butylamino)-6-hydroxy-1-methyl-1,3,5-triazin-2(1H)-one (SYN545666, LM6, nedbr. af Terbutylazin)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	
2,6-Dihydroxy-7,7-dimethyl-6,8-dihydroimidazo[1,2a][1,3,5]triazin-4(6H)-on (LM3)	<0.010	µg/l	AK78 - LC/MS/MS	0.1 µg/l	

Kommentar

Højest tilladelige værdi er overholdt for de undersøgte parametre.

Underleverandør

*1 ALS Czech Republic s.r.o, CAI L1163

Helle Hornemann

Kopimodtagere:

Frederikssund Kommune By og Landskab (vandforsyning, Torvet 2, 3600 Frederikssund)